

Stock No. Job Name: Mark: 3ATU4

Submitted By: Date:4/3/2025

Power Roof Ventilators

Assembled Centrifugal Belt-Drive Upblast Exhaust Ventilator



Designed for use in restaurants, schools, commercial, and industrial applications to exhaust contaminated air from kitchen range hoods, up and away from the roof. Leakproof, spun aluminum construction features a fully rolled windband for increased stability

UL/cUL 762

E53236


- · Aluminum backward inclined, nonoverloading centrifugal wheel design
- Maximum inlet air temperature: 300° F
- NEMA 1 junction box located in motor enclosure
- Optional NEMA 1 and 4 disconnects available Regreaseable pillow block bearings
- UL/cUL 705 Listed for Power Ventilators
- UL/cUL 762 Listed for Restaurant Exhaust Appliances

Air handling quality bearings meet minimum of L10-100,000 hours



r Dayton Electric Mfg. Co. certifies that the ventilators shown herein are licensed to bear the AMCA seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 211 and AMCA Publication 311 and comply with the requirements of the AMCA Certified Ratings Program. c(UL)US LISTED MH12596





D L 13/4" А Square в С Α D 34 3/4 in 30 in 35 3/8 in 21 in

Construction Features

Impeller Diameter (Typ.)	24 in
Impeller Type	Propeller
Impeller Material	Galvanized Steel
Number of Blades	6
Max Inlet Temp	104 °F
Bearing Type	Sealed Pillow Block
Drive Package Description	Drives By Others
Warranty Length	1 Year

Motor Information

Motor Item Number	4YU35
Voltage	115/208-230
Hertz (Cycle)	60 Hz
Motor Phase	1
Motor Enclosure	Open Drip Proof
RPM	1,725 rpm
Full Load Amps	10.6

Other Components

Component	Description	Item #
Fan Description	Exhaust Fan	_
Belt	4L31 (QTY: 1)	4L310
Driver Sheave	1VL44x5/8	3X276
Driven Sheave	AK69H	4HZ83
Driven Bushing	H x 3/4	3X573

Air & Sound Performance

Motor HP	Max BHP	Fan RPM	CFM @	0.000" SP	0.125" SP	0.250" SP	0.375" SP
		Fall KEW					0.375 3P
1/4	0.30	923	CFM	4826	4312	3570	-
			Sones	17.3	17.1	16.8	_
1/3	0.39	1012	CFM	5292	4830	4207	-
			Sones	21.0	20.0	19.9	_
1/2	0.60	1181	CFM	6175	5789	5337	-
			Sones	24.0	26.0	25.0	_
3/4	0.90	1352	CFM	7069	6732	6372	5917
			Sones	30.0	30.0	29.0	29.0

Performance certified is for installation type A: Free inlet, Free outlet. Power rating (BHP) does not include transmission losses. Performance ratings do not include the effects of appurtenances (accessories). The sound ratings shown are loudness values in fan sones at 5 ft. (1.5 m) in a hemispherical free field calculated per AMCA Standard 301. Values shown are for installation type A: Free inlet hemispherical sone levels.

Catalog 405, January 2010

Turns Open	FRPM @ 0 TO	FRPM @ 1/2 TO	FRPM @ 1 TO	FRPM @ 1 1/2 TO	FRPM @ 2 TO	FRPM @ 2 1/2 TO	FRPM @ 3 TO	FRPM @ 3 1/2 TO	FRPM @ 4 TO	FRPM @ 4 1/2 TO	FRPM @ 5 TO	
Approx. FRPM	1075	1049	1023	997	970	944	918	892	866	840	_	