Stock No. Job Name: 4YC86 Mark: Submitted By: Date:4/3/2025

Power Roof Ventilators

Axial Direct-Drive Downblast Exhaust Ventilator



Designed for situations requiring the steady exhaust of air under low to moderate static pressures. Fully rolled baffle bead for stability and ease of transport with spun aluminum hood construction. Galvanized steel venturi, inlet and supports.

- Maximum inlet air temperature: 120° F
- NEMA 1 junction box located in motor enclosure • Optional NEMA 1 and 4 disconnects available
- UL/cUL 705 Listed for Power Ventilators
- Wall or roof mountable



ir Dayton Electric Mfg. Co. certifies that the ventilators shown herein are licensed to bear the AMCA seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 211 and AMCA Publication 311 and comply with the requirements of the AMCA Certified Ratings Program.




 B
 C
 D

 A
 B
 C
 D

 19 in
 24 5/8 in
 15 1/4 in
 5 1/2 in

Performance Characteristics



Construction Features

Impeller Diameter (Typ.)	10 in
Impeller Type	11 in
Impeller Type	Propeller
Backward Inclined Centrifugal	Impeller Material
Impeller Material	Aluminum
Max Inlet Temp	Aluminum
Number of Blades	104 °F
4	Warranty Length
Max Inlet Temp	120 °F
Warranty Length	1 Year

Motor Information

Motor Item Number	4YY56
115	Voltage
Voltage	60 Hz
115	Motor Phase
Hertz (Cycle)	60 Hz
1	Motor Phase
Motor Enclosure	1
Totally Enclosed Air-Over	Motor Enclosure
RPM	Totally Enclosed Air-Over
RPM	1,550 rpm, 1,300 rpm, 1,050 rpm
Full Load Amps	1.5
1,750 rpm	Full Load Amps

Air & Sound Performance

[1
342	280
7.2	7.3
Impeller Diameter (Typ.)	201
	7.6

Performance certified is for installation type A: Free inlet, Free outlet. Performance ratings include the effects of a birdscreen in the airstream. The sound ratings shown are loudness values in fan sones at 5 ft. (1.5 m) in a hemispherical free field calculated per AMCA Standard 301. Values shown are for installation type A: Free inlet hemispherical fan sone levels.

Catalog 405, January 2010